

Verosol Fabrics B.V.
t.a.v. Peter Emmerink
Postbus 15
7150 AA Eibergen
Nederland

Hengelo (ov), 14-8-2019

Test Specimen:	Specimen:	Colour:	Client reference number:
	A.	Grey	SilverScreen 203 - Grijs Polyester / PVC 25% / 75% met een dunne laag aluminium 460 g/m ² – 0,55 mm dik

Examination:	Test number:	Test Name:
	1.	Fire Tests According To BS 5867-2 : 2008 Fabrics for curtains, drapes and window blinds – Part 2 : Flammability requirements – Specification.

Results See following pages


Laboratory Quality Control

This report exists of 2 numbered page(s) and can only be reproduced entirely. All services provided by Textile Lab are subjected to our current Terms and Conditions. The test result relates only to the tested item. Specimens were delivered by client. The interpretation of results and recommendations are for risk of the client and her reader. Regarding to this report Textile Lab does not accept responsibility for any damage caused due to the test results or services. The examined specimens are claimable at the office of Textile Lab within one month after the above-mentioned date. With the exception; when tested for fire/smoke properties, when returned to client or when the material has been consumed. No part of this report may be altered or published, without the prior written permission of the board of directors.

Check this report of 14-8-2019 on authenticity. Page: 1 / 2

Testing • Research • Consulting

Test : 1. Fire Tests – Fabrics for curtains, drapes and window blinds – Part 2: Flammability requirements – Specification.

Norm : BS 5867-2 : 2008
Apparatus : Laboratory equipment

Procedure

Specimens of fabric, Ref: Silver Screen 203, Polyester/PVC 25% / 75% with a thin layer of aluminium, 460 g/m² were subjected to the test method as described in BS EN ISO 15025 : 2002, procedure "A" Surface ignition. The samples were tested in the 'as received' state only. The samples were conditioned for 24 hours in an atmosphere having a temperature of 20 ± 2°C and a relative humidity of 65 ± 5%.

Pre-treatment: None

In certain cases non-durable finishes may be employed to meet the performance requirements of this method, these shall not be subject to pre-treatment. However, if such non-durable finishes are used, the fabric shall clearly be labelled as follows:

WARNING: IF WETTED IN ANY WAY IT IS ESSENTIAL TO RE-TREAT THE FABRIC TO MEET FLAMMABILITY REQUIREMENTS; or:

WARNING: WETTING IN ANY WAY MIGHT REMOVE THE FIRE RESISTING QUALITIES OF THE FABRIC.

Type B performance requirements

No part of any hole nor any part of the lowest boundary of any flame shall reach the top edge or either vertical edge of the sample. If any part of any hole or any part of the lowest boundary of any flame, reaches the top edge or either vertical edge, or if there is any separation of any flaming debris droplets in the testing of one specimen, a further six specimens shall be tested. If all six new specimens comply with the above requirements, the fabric shall be deemed to conform to the requirements for type "B" of the above standard.

Results

The following test results relate only to the ignitability of the combination of materials under the particular conditions of test; they are not intended as a means of assessing the full potential fire hazard of the materials in use. They also only relate to the materials tested. They do not guarantee to represent the performance of production materials.

Results test 1 specimen:	A.					
As received	Warp / Length			Weft / Width		
	1 ↑	2 ↓	3 ↑	1 →	2 ←	3 →
Flames reached edge	No	No	No	No	No	No
Hole reached edge	No	No	No	No	No	No
Flaming debris	No	No	No	No	No	No
Duration of afterflame (s)	0.0	0.0	0.0	0.0	0.0	0.0

Comments

The sample submitted complies with the flammability requirements of BS 5867-2 : 2008 for Type B performance.


Laboratory Quality Control

This report exists of 2 numbered page(s) and can only be reproduced entirely. All services provided by Textile Lab are subjected to our current Terms and Conditions. The test result relates only to the tested item. Specimens where delivered by client. The interpretation of results and recommendations are for risk of the client and her reader. Regarding to this report Textile Lab does not accept responsibility for any damage caused due to the test results or services. The examined specimens are claimable at the office of Textile Lab within one month after the above-mentioned date. With the exception; when tested for fire/smoke properties, when returned to client or when the material has been consumed. No part of this report may be altered or published, without the prior written permission of the board of directors.

Check this report of 14-8-2019 on authenticity. Page: 2 / 2

Testing • Research • Consulting